

From: Martyn White
Sent: 10 September 2021 17:22
To: Maria Tomalova
Subject: AB/102/21/DOC

AB/102/21/DOC

Old Bank House 1 High Street Arundel BN18 9AD

Approval of details reserved by condition imposed under AB/121/20/L relating to condition 2- materials and design (replacement joinery including doors & skirting boards, and drainage & electrical systems for bathrooms/kitchen)

Whilst generally acceptable, I have the following points:

- What will the external extract for the utility room and toilet look like?
- It is not clear why what appears to be standard 'off the peg' internal doors are proposed. How will they relate to the existing openings, and will any alterations be required to accommodate them?
- All other materials for the walling and insulation should be appropriate for a listed building.

Martyn White
Principal Conservation Officer,
Planning Services



Please note: I work on Conservation for half of the working Week (all day Monday and Friday and Tuesday Afternoons)

Arundel District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arundel.gov.uk

Sign up to our newsletter [here](#)

To register to receive notification of planning applications in your area please click on the link below

<https://www1.arundel.gov.uk/planning-application-finder>

