

From: Thomas Callaway
Sent: 28 August 2015 16:25
To: Planning.Responses
Subject: RE: Planning Consultation on AB/106/15/DOC

Percolation tests have been undertaken, however there is no mention of highest recorded groundwater level, or the size of soakaway required for the 1 in 100 year storm event plus 30%. This is especially important where there is limited space, as the soakaways should also be five metres from buildings and services.

More information required

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 20 August 2015 18:03
To: Thomas Callaway
Subject: Planning Consultation on AB/106/15/DOC

To: Engineers (Fluvial Flooding)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION AB/106/15/DOC

NO:

Registered: 04-AUG-15

Site Address: 55/57 High Street Arundel BN18 9AJ

Description of Application for approval of details reserved by condition

Works: imposed under AB/41/12 relating to Condition No's 3, 4 and 8 -
Schedule of materials, cycle storage & Drainage details

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 3rd September 2015.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
