



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Mr R Hole
Tahrah
Maxwell Road
Arundel
West Sussex
BN18 8EU

Your Ref: AB/13/18/DOC

Please ask for:

Mrs A Gardner

13 March 2018

Dear Mr R Hole

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Application for discharge of conditions imposed under planning permission AB/37/17/PL relating to
condition No. 3 (materials), 4 (Discharge of any flows to watercourse), 5 (Access & maintenance of
any watercourse) & 6 (Flood risk assessment)
Tahrah Maxwell Road, Arundel,

Notification regarding the above application:

Condition Number 4

The development shall not proceed until formal consent has been approved in writing from the Lead Local Flood Authority (WSCC) or its agent (ADC) for the discharge of any flows to watercourses, or the culverting, diversion, infilling or obstruction of any watercourse on the site.

Any discharge to a watercourse must be at a rate no greater than the pre-development run off values.

Reason : To ensure that the proposed development is satisfactorily drained in accordance with policies GEN7 and GEN9 of the Arun District Council Local Plan.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

This condition is discharged on the basis of the information submitted in the applicant's letter dated 07-02-2018 namely RWP to water butt and utilising existing water RWP.

You will need to ensure the pipe entrance remains visible/accessible/maintained, together with any sections of ditch that remain. It is appreciated that the system no longer receives the flows that it once used to, however, it will still receive local runoff.

To help in regard to maintenance, it is highly recommended that a concrete bag headwall or similar approved, is constructed on the end of the pipe. Please contact the Council's Drainage Engineers so that they can agree the details. The owner of the property will have a riparian (legal) responsibility to maintain the section of pipe/ditch within the property boundary.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning