

Conservation Area Advisory Committee

Meeting Date : 5 January 2015

Ref	Description	Address	Design award
AB/150/14/L	Application for Listed Building Consent to replace roof - replace rotten timber to gutter and renew using code 5 lead, felt roof breathable membrane and 50mm x 25mm treated timber batten. Fix new natural top graded slates using 38mm copper nails. Ridge tiles to be reused or clay angled tiles to match existing. Insertion of a top hung velux conservation roof window on the South facing slope.	12 Tarrant Street Arundel	
Comments:	<i>as above</i> <i>DPS</i>		
Suggested Conditions:			