


scan


AB/31/18/DOC

CLARENDON PROPERTIES LTD

1 The Square, Prinsted Lane, Prinsted
PO10 8HT.



Anita Gardner
First Floor,
Arun Civic Centre,
Maltravers Road,
Littlehampton,
BN17 5LF



Please treat as a DOC

23rd March 2018

Dear Anita


AB/151/17/DOC

As previously discussed, please find enclosed the revised structural survey and the working drawings, along with a sample of the timber to be utilized for the cladding to satisfy conditions 4&5

The timber is Accoya, which is an acetylated treated softwood which has a long durability against rot and fungus and which, due to the treatment of the timber will naturally silver in a shorter period of time than any other timber cladding. This is to be used as a vertical strip running up the side of the building and over the roof so as to appear as a continuous strip. The profile is 80mm wide strip with a 30mm gap between the timbers.

Please feel free to give me a call if the enclosed is unclear

Kind regards



Giles Dixon