ADC Planning Consultation
Response from the Historic Buildings Adviser

Application Number	AB/38/14/DOC
Address	14 Orchard Place Arundel BN18 9BP
Description	Application for the approval of conditions 3 & 6 of previously approved Listed Building Consent AB/59/13/L - relating to joinery & external walls & roof.
Case Officer	Anita Gardner
Site Visit	

Comment

These details are largely acceptable with the exception of the window joinery details on drawing BR-09A.These appear to show 'storm' window design rather than a flush type as normally required.

On this basis condition 3 cannot be recommended for discharge.

Ian Wightman
Historic Buildings Adviser

Please note: The observations and comments expressed on this sheet are the views of the consultee concerned and are in no way binding on either the Council or its senior officers when making a decision on the application. Applicants or their agents should contact the case officer before acting on these views.