

Sandra Edwards

From: Amanda Scholes on behalf of Planning.Responses
Sent: 15 May 2017 11:39
To: Planning Scanning
Subject: FW: Planning Consultation on AB/56/17/DOC

From: Paul Cann
Sent: 15 May 2017 11:31
To: Planning.Responses
Subject: RE: Planning Consultation on AB/56/17/DOC

Comments;

The principle has been agreed by my former colleague, Tom Callaway, however the construction detail (cross section) for the crated soakaway needs to be representative of what is proposed. I.e. no overflow pipe, specify pipe inlet levels, soakaway base levels, pipe diameter, crate depth, etc.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 08 May 2017 15:03
To: Paul Cann
Subject: Planning Consultation on AB/56/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990
APPLICATION AB/56/17/DOC

NO:

Registered: 04-MAY-17
Site Address: 15 Queens Lane Arundel BN18 9JW

Description of Works: Application for approval of details reserved by condition no 5 imposed on planning reference AB/14/16/PL relating to surface water drainage

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 22nd May 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
