



---

Dear Anita,

We have the following comments regarding condition 9:


1. Please can a site specific construction detail drawing of the hydrobrake be provided.
2. Please adjust layout to include silt traps prior to all connections to permeable paving on plan.
3. Please provide finish and formation levels of permeable paving.
4. Please provide dimensions and construction detail for permeable pipe through sub-base.

Please re-consult us once this information has been supplied.

Kind regards,



Down Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.