

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 21 July 2020 16:17
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: AB/63/20/DOC 74-76 Canada Road

Please scan as correspondence with agent

Anita Gardner
Principal Planning Officer,
Directorate of Place

T: 01903 737529
E: anita.gardner@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Anita Gardner
Sent: 21 July 2020 16:16
To: Pendry, Glenn [REDACTED]
Subject: FW: AB/63/20/DOC 74-76 Canada Road

Dear Glenn,
Please see the comments of our drainage engineer below.
Can you let me have a timeframe for receipt of this additional information?
Regards
Anita Gardner

Anita Gardner
Principal Planning Officer,
Directorate of Place

T: 01903 737529
E: anita.gardner@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Laura Gibbons [REDACTED]
Sent: 21 July 2020 15:34
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: AB/63/20/DOC

Dear Anita,

We have the following comments regarding condition 9:

1. Please can a site specific construction detail drawing of the hydrobrake be provided.
2. Please adjust layout to include silt traps prior to all connections to permeable paving on plan.
3. Please provide finish and formation levels of permeable paving.
4. Please provide dimensions and construction detail for permeable pipe through sub-base.

Please re-consult us once this information has been supplied.

Kind regards,

Laura Gibbons
Engineer, Adur & Worthing Councils

Website: www.adur-worthing.gov.uk

Address: Facilities & Technical Services, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

LGO Awards
2020

Council of the Year
FINALIST



This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.