



Martin Harvey
Reilly Construction Ltd
C/o Martin J. Harvey
3 Marden Way
Petersfield
Hampshire
GU31 4PW

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

11 December 2014

Our Ref: SWS-SUSXW-CC-002519

Level 1: Wastewater and Surface water capacity check application for: Bevin & Bevin, Brewery Hill, Arundel, West Sussex, BN18 9DQ.

Dear Mr. Harvey,

Thank you for the additional information that we requested in respect of the above development.

We will process your application for foul and respond to you as quickly as we can.

Also please note that, as the development site is having existing connection the proposed surface water flow could be accommodated if the existing surface water flows from the existing premises are equivalent or greater than the proposed surface water flow and are removed as part of the redevelopment of the site. You will be required to provide a topographical site survey and/or a CCTV survey with the connection application showing the existing connection points, pipe sizes, gradients and calculations confirming the proposed surface water flow will be no greater than the existing contributing flows.

If your request is for a level 1 capacity check you should receive a response after 15 working days from the date of this letter. However, if you have applied for a level 2 this may take up to 25 working days to complete.

Please quote the above reference number in all correspondence relating to this application.

Yours sincerely,

Developer Se