

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 01 June 2017 08:28
To: Planning Scanning
Subject: FW: Planning Consultation on AB/66/17/DOC

From: Paul Cann
Sent: 31 May 2017 16:49
To: Planning.Responses
Subject: RE: Planning Consultation on AB/66/17/DOC

Surface Water Drainage:

I understand that infiltration has been ruled out on this site and note the applicant is intending to utilise existing connections, to what we believe is a highway drainage system, that is the responsibility of West Sussex County Council.

As a result, the applicant needs to provide evidence that WSCC are happy with the proposals. I would suggest the applicant discusses the scheme with Kevin Macknay at WSCC.

It is also noted that the drainage of courtyards/roof drainage is subject to confirmation of finished levels/further investigations – The DOC needs to comprise the full drainage scheme for consideration.

Any surface water drainage to be abandoned to be grubbed out or filled with concrete (add note to drawings).

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

Sent: 23 May 2017 14:49
To: Paul Cann
Subject: Planning Consultation on AB/66/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION **AB/66/17/DOC**

NO:

Registered: 10-MAY-17

Site Address: Eagle Brewery Yard Brewery Hill Arundel BN18 9DH

Description of Works: Application for approval of details reserved by condition imposed under AB/104/13 relating to conditions 10 & 13 - surface water drainage

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 6th June 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
