

Arun District Council
Development Control
1, Arun Civic Centre Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2018/120608/01-L01

Your ref: AB/73/18/PL

Date: 22 August 2018

Dear Sir/Madam

**DEMOLITION OF GARAGE & ERECTION OF 2NO. DWELLINGS WITH
ASSOCIATED CAR PARKING AND LANDSCAPING**

18 QUEENS LANE ARUNDEL BN18 9JN

Thank you for the consultation on the above application, please quote our reference on all correspondence.

Environment Agency position

The proposed development will only meet the requirements of the National Planning Policy Framework if the following measure(s) as detailed in the Flood Risk Assessment (June 2018) submitted with this application are implemented and secured by way of a planning condition on any planning permission.

The development permitted by this planning permission shall only be carried out in accordance with the approved Flood Risk Assessment (FRA) (June 2018) and the following mitigation measures detailed within the FRA:

- **Finished floor levels for the first floor, where habitable rooms are proposed, are set no lower than 4.10 metres above Ordnance Datum (AOD).**

The mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the timing / phasing arrangements embodied within the scheme, or within any other period as may subsequently be agreed, in writing, by the local planning authority.

Reason

To reduce the risk of flooding to the proposed development and future occupants.

Environment Agency
Canal Walk, ROMSEY, Hampshire, SO51 7LP.

[Redacted signature block]

Cont'd..

Informatives

We recommend that the owner/occupants sign up to the Environment Agency Flood Warning Service and have a flood evacuation plan.

Please note that it is not our role to assess any details on flood evacuation or emergency plans, as we do not carry out these roles during a flood. Our involvement with this development during an emergency will be limited to delivering flood warnings to occupants/ users covered by our flood warning network.

In all circumstances where warning and emergency response is fundamental to managing flood risk, we advise LPAs to formally consider the emergency planning and rescue implications of new development in making their decisions. The PPG states that LPAs should consult their emergency planning staff to ensure evacuation plans are suitable through appropriate planning conditions (PPG Ref ID: 7-057-20140306).

We therefore recommend seeking comments from your Local Authority emergency planners.

We recommend that consideration be given to use of flood mitigation measures to reduce the impact of flooding when it occurs. Flood mitigation measures include barriers on ground floor doors, windows and access points and bringing in electrical services into the building at a high level so that plugs are located above possible flood levels. More information can be found in the communities and local Government publication 'Improving the flood performance of new buildings' which can be viewed at:

<http://www.communities.gov.uk/publications/planningandbuilding/improvingflood>

Any works in, over, under or within 5 metres of the IDB ditch located at the southern boundary of the property will require a Flood Defence Consent from the Environment Agency. For more information please contact [REDACTED]

Your responsibilities and rules to follow for watercourses on or near your property, and permissions you need to do work around them can be found at

<https://www.gov.uk/guidance/owning-a-watercourse>.

Yours faithfully

Miss Suz Greenwood
Planning Advisor, Environment Agency

[REDACTED]

Cont/d..

