



Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management
Procedure) (England) Order 2015
Application for Planning Permission
DECISION NOTICE

Application Ref: AB/73/18/PL

1 To Addressee

Savills
 23 Kings Hill Avenue
 West Malling
 Maidstone
 ME19 4UA

2 Site Address

Land adj 18 Queens Lane
 Arundel
 BN18 9JN

3 Description of Development

Demolition of garage & erection of 2No. dwellings with associated car parking and landscaping

In pursuance of their powers under this Act and related Orders and Regulations the Council **PERMIT** this development to be carried out in accordance with the application and plans and subject to the following conditions

- 1 The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.

Reason: To comply with Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby approved shall be carried out in accordance with the following approved plans:

001 Rev A
 100 Rev A
 200
 300

Reason: For the avoidance of doubt and in the interests of amenity and the environment in accordance with policy D DM1 of the Arun Local Plan.

- 3 The development permitted by this planning permission shall only be carried out in accordance with the approved Flood Risk Assessment (FRA) (June 2018) and the following mitigation measures detailed within the FRA:
- Finished floor levels for the first floor, where habitable rooms are proposed, are set no lower than 4.10 metres above Ordnance Datum (AOD).
- The mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the timing / phasing arrangements embodied within the scheme, or within any other period as may subsequently be agreed, in writing, by the Local Planning Authority.
- Reason: To reduce the risk of flooding to the proposed development and future occupants in accordance with Policy WDM2 of the Arun Local Plan.
- 4 Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority.
- The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.
- Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage.
- No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.
- Reason : To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.
- 5 No part of the development shall be first occupied until the ground floor car parking spaces have been constructed in accordance with those shown on plan 100 Rev A. These spaces shall thereafter be retained at all times for their designated car parking purpose.
- Reason: To provide car parking space for the use and in accordance with policy T SP1 of the Arun Local Plan.

- 6 The development shall not commence until formal consent has been approved in writing from the Lead Local Flood Authority (WSCC) or its agent (ADC) for the discharge of any flows to watercourses, or the culverting, diversion, infilling or obstruction of any watercourse on the site. Any discharge to a watercourse must be at a rate no greater than the pre-development run off values.

Reason : To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1 and W DM2 of the Arun Local Plan. It is considered necessary for this to be a pre-commencement condition to protect existing watercourses prior to the construction commencing.

- 7 The development layout shall not be agreed until such time that arrangements for the future access and maintenance of any watercourse or culvert (piped watercourse) crossing or abutting the site has been submitted and approved in writing by the Local Planning Authority. No construction is permitted, which will restrict current and future land owners from undertaking their riparian maintenance responsibilities of any watercourse on or adjacent to the site.

Reason : To ensure that the duties and responsibilities, as required under the Land Drainage Act 1991, and amended by the Flood and Water Management Act 2010, can be fulfilled without additional impediment following the development completion, in accordance with Policies W DM1, W DM2 and W DM3 of the Arun Local Plan.

- 8 No part of the development shall be first occupied until covered and secure cycle parking spaces have been provided in accordance with plans and details submitted to and approved by the Local Planning Authority.

Reason: To provide alternative travel options to the use of the car in accordance with policies TSP1 and TDM1 of the Arun Local Plan.

- 9 The north side glazed screen serving the proposed balconies, shall measure a height of 1.7 metres and shall be obscurely glazed to the satisfaction of the Local Planning Authority, before first occupation and shall remain so at all times thereafter.

Reason: To protect the amenities and privacy of the adjoining property in accordance with policies D DM1 of the Arun Local Plan.

INFORMATIVE: Drainage Engineers advise that Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE 365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 30% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers. Supplementary guidance notes are also available on request.

A formal application for connection to the public sewerage system is required in order to

service this development, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk. Please read our New Connections Services Charging Arrangements documents which is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructurecharges>.

INFORMATIVE: It is recommended that the owner/occupants sign up to the Environment Agency Flood Warning Service and have a flood evacuation plan.

INFORMATIVE: We recommend that consideration be given to use of flood mitigation measures to reduce the impact of flooding when it occurs. Flood mitigation measures include barriers on ground floor doors, windows and access points and bringing in electrical services into the building at a high level so that plugs are located above possible flood levels. More information can be found in the communities and local Government publication 'Improving the flood performance of new buildings' which can be viewed at: <http://www.communities.gov.uk/publications/planningandbuilding/improvingflood>

INFORMATIVE: Any works in, over, under or within 5 metres of the IDB ditch located at the southern boundary of the property will require a Flood Defence Consent from the Environment Agency. For more information please contact PSOWestSussex@environmentagency.gov.uk.

Your responsibilities and rules to follow for watercourses on or near your property, and permissions you need to do work around them can be found at <https://www.gov.uk/guidance/owning-a-watercourse>.

INFORMATIVE: Statement pursuant to Article 35 of the Town and Country Planning (Development Management Procedure)(England) Order 2015. The Local Planning Authority has acted positively and proactively in determining this application by assessing the proposal against all material considerations, including planning policies and any representations that may have been received and subsequently determining to grant planning permission in accordance with the presumption in favour of sustainable development, as set out within the National Planning Policy Framework.



Neil Crowther
Group Head of Planning

Case Officer: Richard Castro-Parker

Date of Decision:

13 December 2018

Arun District Council
The Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF

IT IS IMPORTANT THAT YOU READ THE NOTES ATTACHED TO THIS DOCUMENT

APPEALS TO THE SECRETARY OF STATE

If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.

If this is a decision on a planning application relating to the same or substantially the same land and development as is already the subject of an enforcement notice, and you want to appeal against this planning application decision, then you must do so within 28 days of the date of this notice.

If an enforcement notice is served relating to the same or substantially the same land and development as in your application and you want to appeal against this planning application decision, then you must do so within 28 days of the date of service of the enforcement notice, or within 12 weeks of the date of this notice, whichever period expires earlier.

Otherwise, if you want to appeal against this decision then you must do so within 6 months of the date of this notice.

Appeals must be using a form which you can get from the Secretary of State at Temple Quay House, 2 The Square, Temple Quay, Bristol BS1 6PN (Tel: 0303 444 5000) or online at <http://acp.planninginspectorate.gov.uk>

The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to the Secretary of State that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

PURCHASE NOTICES

If either the local planning authority or the Secretary of State refused permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances, the owner may serve a purchase notice on the Council (that is, where the land is situated in a National Park, the National Park authority for the Park, or in any other case the district council in whose area the land is situated). This notice will require the Council to purchase the owner's interest in the land in accordance with the provisions of Chapter 1 of Part VI of the Town & Country Planning Act 1990.

Please note that this decision notice only relates to matters under the Planning Acts and does not give consent under any other legislation that may apply to the development. You will need to carry out your own checks to determine whether any other consents or permissions are required. For example, the Building Regulations are likely to apply to most developments, and a Highways Licence may be required from West Sussex County Council for any development within the