

**ADC Planning Consultation
Response from the Historic Buildings Adviser**

Application Number	AB/82/15/DOC
Address	Bevin and Bevin, River Road, Arundel, BN18 9DH
Description	Application for approval of matters reserved by condition imposed under AB/104/13/ relating to condition 4 for a 'statement of detail' for windows & doors.
Case Officer	Anita Gardner
Site Visit	Previous

Comment

Condition 4: The details show three different windows in elevation however there are no sections showing window depth or the thickness of glazing.

The window details for units 6-7 show the window multi-paned however these are separated only by a single line. Please confirm whether this is meant to represent glazing bars and if it is can it be redrawn.

The brick arch for units 8-10 appears to show bricks angled rather than rubbed. Please confirm the exact detail for these.

Given the above issues the Condition cannot be recommended for discharge.

Ian Wightman

Senior Historic Buildings Adviser

19th August 2015

Please note: The observations and comments expressed on this sheet are the views of the consultee concerned and are in no way binding on either the Council or its senior officers when making a decision on the application. Applicants or their agents should contact the case officer before acting on these views.