

Rhiannon Lloyd

From: Rhiannon Lloyd
Sent: 12 November 2024 10:47
To: REDACTED
Subject: AB/94/24/CLP - 47A King Street

Good morning,

I am the case officer for this application. I note that the solar panels are described as a 0.3m depth. This is problematic as the General Permitted Development Order which this application is assessed against, states solar thermal equipment cannot protrude more than 0.2m beyond the roof slope.

Please can you confirm you can amend the choice of solar panels, so that they comply with the 0.2m depth. Please provide amended plans so that we can continue with the application.

Kind regards,
Rhiannon

Rhiannon Lloyd (she/her)
Planner (Degree Apprentice), Planning

T: 01903 737637
E: rhiannon.lloyd@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to [Planning application finder \(arun.gov.uk\)](http://Planning application finder (arun.gov.uk)).

