



September -17-2017
Ref ALR-butl/Htg-02-17

For The Attention of Mr Mike Rees

Butlers
26 Tarrant Street,
Arundel
West Sussex
BN18 9DG.

Dear Mr Rees

Further to my site visit on 17th of August 2017, I can confirm the noise reading I took regarding the new air-conditioning condensers recently fitted.

The test took place at approximately 3.45 pm over a period of 10 minutes. The equipment controls were set to full cooling and full heating during the whole test. The reading did not fall below 51db and did not rise above 53db and was taken at three meters from the equipment.

I would expect the new Media condensers would be approximately 15%-20% quieter than the previous LG condensers as the new condensers have inverter driven compressors.

Should you have any further queries please do not hesitate to contact me

Yours faithfully

Andrew Roberts
Contracts manager