

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 11 October 2017 10:30
To: Planning Scanning
Subject: FW: AB/96/17/PL - 3 air conditioning units Butlers Bar 25 Tarrant Street, Arundel

Environmental health consultee response

From: Anita Gardner
Sent: 10 October 2017 12:43
To: Planning.Responses
Subject: FW: AB/96/17/PL - 3 air conditioning units Butlers Bar 25 Tarrant Street, Arundel

Please treat as a consultee response

Anita Gardner | Principal Planner, Directorate of Place, [Arun District Council](http://www.arun.gov.uk) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Carol Reynolds
Sent: 10 October 2017 12:36
To: Anita Gardner
Subject: RE: AB/96/17/PL - 3 air conditioning units Butlers Bar 25 Tarrant Street, Arundel

Dear Anita,

Thank you for forwarding Mr Andrew Roberts' letter, 17 September 2017, for my attention. This refers to noise readings carried out by him in respect of the above Planning Application in his position as Contracts Manager for 'ICE,' Air Conditioning Units (etc) provider. Unfortunately, this does not constitute an Acoustic Report carried out in accordance with the provisions of BS4142. My comments, 8th September 2017 therefor still apply. I look forward to receiving such a Report together with mitigation measures that may be necessary to safeguard the amenity of nearby residents.

Kind regards

Carol

From: Anita Gardner
Sent: 28 September 2017 11:23
To: Carol Reynolds
Subject: FW: AB/96/17/PL - 3 air conditioning units Butlers Bar 25 Tarrant Street, Arundel

Carol,

The attached letter has been received in response to my request for further information. Does this satisfactorily address your concerns?

Thanks

Anita

Anita Gardner | Principal Planner, Directorate of Place, [Arun District Council](http://www.arun.gov.uk) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF



From:

Sent: 28 September 2017 11:17

To: Anita Gardner

Cc: Clint Clements

Subject: Re: AB/96/17/PL - 3 air conditioning units Butlers Bar 25 Tarrant Street, Arundel

Dear Anita

Please find attached the sound report letter provided by the air conditioning company.

While this stops short of a full acoustic report to BS4142, it shows that sound levels are very low and unlikely to be perceptible in a town centre location adjacent to a public car park, and it does appear to provide the additional information requested by your environmental health consultant.

Should you require further information please contact me.

Kind regards

Clint

Clint Clements BA (Arch) MRICS MCIOB
Chartered Building Surveyor for Downland Design Ltd

On 13 Sep 2017, at 15:05, Anita Gardner [REDACTED] wrote:

Dear Mr Clements

Further to your telephone message please see the attached environmental health officer's comments.

Accordingly, I would appreciate receipt of this additional information within the next 2 weeks. To allow time for receipt and re-consultation with our environmental health officer's I would be grateful for your agreement to an extension of time until 17-10-2017.

Regards

Anita Gardner

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

NLPG UPRN 100062237016

DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this

disclaimer includes any attachments.

<25 tarrant street.pdf>