

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 20 January 2020 12:34
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Karen Garner <Karen.Garner@arun.gov.uk>
Subject: AL/106/19/DOC

Dear Karen,

Environmental Health are happy with the EV charging points and are happy for Condition 15 to be discharged.

With regard to condition 10 (CMP), please could the applicant expand on two points. Site Lighting – what measures will be taken in the event of a complaint. Secondly, noise prevention – please could this section be revised in much more detail. Given the history of noise complaints we have already had with this site, I am not satisfied that the information provided in this section is sufficient.

Lighting – condition 7, some lighting was shown on one of the engineers maps, but I couldn't find any confirmation within the application that the lighting scheme proposed complies with the Institute of Lighting Professionals Guidance Zone E2. Please could this be confirmed.

In summary, Environmental Health are happy for Condition 15 to be discharged, but require further information on Conditions 7 and 10.

Regards

Fiona

Fiona Fitzgerald | Senior Environmental Health Officer, Environmental Health, Arun District Council | Location: Third Floor, Arun Civic Centre, Maitravers Road, Littlehampton, BN17 5LF

Internal: 37674 | External: +44(0)1903 737674 | E-mail: fiona.fitzgerald@arun.gov.uk



Save the environment - think before you print.



Visit Arun's web site at www.arun.gov.uk