

## Simon Davis

---

**From:** Tim Button [REDACTED]  
**Sent:** 14 September 2021 12:31  
**To:** Laura Gibbons; Planning.Responses  
**Cc:** Simon Davis  
**Subject:** RE: Planning Consultation on: AL/112/21/DOC  
**Attachments:** (435050) Springfields, Aldingbourne - SW Network Calculations.pdf

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Good Afternoon Laura,

Please see the calculations attached, these were meant to have been uploaded with all the other documents when the app was created. I shall get these updated onto the application today.

With regards to the infiltration testing; the results supplied were from testing carried out to BRE 365, but from the month of September. These results showed that percolation was unachievable thus the SuDS hierarchy was followed, so can you please clarify why it's necessary to carry this out again in winter months?

Will you accept groundwater monitoring within the month of October, bearing in mind strikes in January were recorded at depths greater than 1m and that we're using a shallow attenuation system.

We shall work through your other comments and send over once complete.

Regards

Tim Button

For and on behalf of Cowan Consultancy Ltd.

[REDACTED]

**COWAN CONSULTANCY LTD**  
3 Turnberry House – 4400 Parkway - Whiteley  
Fareham - Hampshire - PO15 7FJ

[REDACTED]

\*\*\*\*\*  
This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the system manager.

This footnote also confirms that this email message has been swept by Panda - Global Virus Insurance for the presence of computer viruses.

\*\*\*\*\*

*Cowan Consultancy Ltd - Registered No 3523251 England.*