

Julie Grieves

From: Paul Cann
Sent: 28 January 2013 12:41
To: Planningecons
Subject: RE: Planning Consultation on: AL/117/12/

Engineers comments in respect to drainage:

The applicant does not state how surface water will be disposed of. A SuDS system (Sustainable Urban Drainage System) must be investigated for surface water disposal, ie. soakage structures.

Please apply standard condition ENGD2A.

Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests and design must be carried out in accordance with BRE 365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 30% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location.

Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design.

The applicant proposes a sewage treatment plant for the disposal of foul sewerage. The Environment Agency should be consulted in this respect, as consent will be required. Please apply standard condition ENGD1A.

Paul Cann
Senior Engineer (Drainage & Coastal)

[Paul Cann](#) | Senior Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk
Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From:
planningecons@arun.gov.uk

[\[mailto:planningecons@arun.gov.uk\]](mailto:planningecons@arun.gov.uk)

Sent: 03 January 2013 13:01

To: Land Drainage

Subject: Planning Consultation on: AL/117/12/

DO NOT DELETE

To: **Engineers (Fluvial Flooding)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2010 (as amended)

Planning Permission

APPLICATION NO:	AL/117/12/
Registered:	12th December 2012
Site Address:	The Old Barn Arundel Road Fontwell BN18 0SX
Grid Reference:	494631 107339
Description of Works:	Change of use of land for the siting of a second mobile home and storage of two caravan units for Travelling Show Persons. Departure from the Development Plan.

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 10-JAN-13.

You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Miss K Rawlins who can be contacted on telephone number 01903 737500 x 37314.

Regards
Planning Officer