



WEST SUSSEX COUNTY COUNCIL
WEST SUSSEX FIRE AND RESCUE SERVICE

HYDRANT CONDITION CONSULTATION WITH PLANNING AUTHORITY

Date: 17.04.2025

To: Hannah Kersley From: Ian Stocks

Planning Ref: AL/118/24/PL

Address: Belle Vue Level Mare Lane Eastergate PO20 3SA

Description: 3 No dwellings with associated parking. This application is in CIL Zone 3 and is CIL Liable as dwellings. This application is a Departure from the Development Plan.

Date of visit: N/A

RECOMMENDATION

Advice: x Modification: More Information:
Objection: No Objection: Refusal:

Total number of hydrants required 1

This application has been dealt with in accordance with the statutory obligation placed upon Fire and Rescue Service by the following act;

Fire and Rescue Services Act 2004
Part 5, 38: Duty to secure water supply etc.

1) *A fire and rescue authority must take all reasonable measures for securing that an adequate supply of water will be available for the authority's use in the event of fire.*

This proposal has been considered by means of desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC mapping and Fire and Rescue Service information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments:

- 1) Prior to the commencement of the development details showing the proposed location of [1] one fire hydrant or stored water supply (in accordance with the West Sussex Fire and Rescue Guidance Notes) shall be submitted to and approved in writing by the Local Planning Authority in consultation with West Sussex County Council's Fire and Rescue Service. These approvals shall not be unreasonably withheld or delayed.
- 2) Prior to the first occupation of any dwelling forming part of the proposed development that they will at their own expense install the fire hydrant in the approved location to BS 750 standards or stored water supply and arrange for their connection to a water supply which is appropriate in terms of both pressure and volume for the purposes of firefighting.
- 3) Prior to the first occupation of any dwelling forming part of the proposed development they will notify the West Sussex County Council's Fire and Rescue Service that the fire hydrant(s) have been installed and are operational, to ensure that the Fire and Rescue Service are aware that the hydrant(s) is/are now a usable asset in the event of a fire.

The fire hydrant shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

As part of the Building Regulations 2004, adequate access for firefighting vehicles and equipment from the public highway must be available and may require additional works on or off site, particularly in very large developments. (BS9999 2017 Section 21) for further information please contact the Fire and Rescue Service.


If a requirement for additional water supply is identified by the Fire and Rescue Service and is subsequently not supplied, there is an increased risk for the Service to control a potential fire. It is therefore recommended that the hydrant condition is implemented.

Reason: In the interests of amenity and in accordance with policy INF SP1 and TSP1 of the Arun Local Plan 2011-2031 and in accordance with The Fire & Rescue Service Act 2004.

Ian Stocks
Water and Access Manager



West Sussex Fire & Rescue response



Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notifications of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



From: FRS Water and Access [REDACTED]
Sent: 17 April 2025 15:07
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Large Development Hydrant Condition - AL/118/24/FUL Belle Vue Level Mare Lane Eastergate
PO20 3SA

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

FAO: Hannah Kersley

Dear Hannah,

Please find attached a planning condition for application no. AL/118/24/FUL for the requirement of additional fire hydrant(s) for the proposed development. This is to ensure that all dwellings on the proposed site are within 150 metres of a fire hydrant for the supply of water for firefighting. If an alternative water supply for firefighting is to be considered it will need to conform with the requirements identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service. Evidence will also be required that Fire Service vehicle access meets with the requirements identified in AD-B Volume 1: B5 - Section 13, including Table 13.1 and diagram 13.1.

Regards
Ian



Ian Stocks


Water & Access Manager - Protection
West Sussex Fire & Rescue Service

Web www.westsussex.gov.uk/fire

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
