



Local Policing Support Team

Your Ref: AL/141/21/RES

Our Ref: LM/ARU/20/05B

Date 12th January 2022

Contact Name: Lee Melbourne

Dear Mr Davis,

RE: Land North of Lee's Yard Lidsey Road Woodgate PO20 3SU

Thank you for your correspondence of the 11th of January 2022, advising me of a planning application for approval of reserved matters following outline planning permission AL/21/20/OUT for the approval of the appearance, layout, scale and landscaping for 5 No 4-bed dwellings, 14 No 3-bed dwellings & 19 No 2-bed dwellings. This site is in CIL Zone 3 and is CIL Liable as new dwellings at the above location, for which you seek advice from a crime prevention viewpoint.

The National Planning Policy Framework demonstrates the government's aim to achieve healthy, inclusive and safe places which are safe and accessible, so that crime and disorder, and the fear of crime, do not undermine the quality of life or community cohesion – for example through the use of attractive, well-designed, clear and legible pedestrian and cycle routes, and high-quality public space, which encourage the active and continual use of public areas.

With the level of crime and anti-social behaviour in the Arun District being average when compared with the rest of Sussex, I have no major concerns with the proposals, however, additional measures to mitigate against any identified local crime trends and site specific requirements should always be considered.

I have had the opportunity to examine the detail within the application and in an attempt to reduce the opportunity for crime and the fear of crime I offer the following comments from a Secured by Design (SBD) perspective. SBD is owned by the UK Police service and supported by the Home Office and Building Control Departments in England (Part Q Security – Dwellings), that recommends a minimum standard of security using proven, tested and accredited products. Further details can be found at www.securedbydesign.com

I refer the applicant to previous correspondence from this office Your Ref: AL/21/20/OUT dated the 11th March 2020 and Our Ref: LM/ARU/20/05A dated the 12th March 2020 to which all comments remain extant.

Mr Davis
Planning Officer
Planning Control
Arun District Council

Sussex Police Headquarters
Malling House, Malling, Lewes, East Sussex, BN7 2DZ

I direct the applicant or their agent to our website at www.securedbydesign.com where the SBD Homes 2019 Version 2 document can be found. The Secured by Design scheme is a Police initiative to guide and encourage those engaged within the specification, design and build of new homes, and those undertaking major or minor property refurbishment, to adopt crime prevention measures. The advice given in this guide has been proven to reduce the opportunity for crime and the fear of crime, creating safer, more secure and sustainable environments.

The development has outward facing dwellings which has created a good active frontage with the streets and the public areas being overlooked.

Parking has been provided primarily on plot. Where communal parking occurs, it is important that they must be within view of an active room within the property. An active room is where there is direct and visual connection between the room and the street or the car parking area. Such visual connections can be expected from rooms such as kitchens and living rooms, but not from bedrooms and bathrooms

For advice pertaining to dwelling entrance door sets and windows within the development I refer the applicant to chapters 21 & 22 of the SBD Homes Version 2 2019 document.

With regards to footpath design throughout the development I refer the applicant to the SBD Homes 2019 Version 2 document chapter 8.

With regards to landscaping - ground planting should not be higher than 1 metre with tree canopies no lower than 2 metres. This arrangement provides a window of observation throughout the area.


In relation to the LEAP - areas of play should be situated in an environment that is stimulating and safe for all children, be overlooked with good natural surveillance to ensure the safety of users and the protection of equipment, which can be vulnerable to misuse. They should be designed to allow natural surveillance from nearby dwellings with safe and accessible routes for users to come and go. Boundaries between public and private space should be clearly defined and open spaces must have features which prevent unauthorised vehicular access. I would ask that the LEAP is surrounded with railings with self-closing gates to provide a dog free environment.

Finally, lighting throughout the development will be an important consideration and where it is implemented it should conform to the recommendations within BS5489-1:2020

Thank you for giving me an opportunity to comment.

The Crime & Disorder Act 1998 heightens the importance of taking crime prevention into account when planning decisions are made. Section 17 of the Act places a clear duty on both police and local authorities to exercise their various functions with due regard to the likely effect on the prevention of crime and disorder. You are asked to accord due weight to the advice offered in this letter which would demonstrate your authority's commitment to work in partnership and comply with the spirit of The Crime & Disorder Act.

Yours sincerely



Miss Lee A Melbourne
Designing Out Crime Officer
Sussex Police Headquarters

Sussex Police Headquarters
Malling House, Malling, Lewes, East Sussex,
BN7 2DZ

