

Please upload as parish consultation response

From: Paul Cann
Sent: 27 February 2018 12:43
To: Planning.Responses
Subject: RE: Planning Consultation on AL/18/18/DOC

Condition can now be discharged.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 26 February 2018 16:03
To: Paul Cann
Subject: Planning Consultation on AL/18/18/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION AL/18/18/DOC

NO:

Registered: 06-FEB-18

Site Address: Medowsley Westergate Street Aldingbourne PO20 3QS

Description of Approval of details reserved by conditions imposed under

Works: AL/4/17/HH relating to Conditions 3 - Surface Water Drainage plan & constuction details

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditons relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 12th March 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Richard Temple who can be contacted on telephone number 01903 737591.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
