

[REDACTED]

From: Amanda Scholes on behalf of Planning.Responses
Sent: 20 November 2018 08:10
To: Planning Scanning
Subject: FW: Land at Lidsey AL/20/18/OUT
Attachments: SP_OCL_SR_502_B.pdf

Importance: High

From: Michael Eastham
Sent: 19 November 2018 16:24
To: 'Tim Townsend'
Cc: 'SU.Local.Development' [REDACTED] Planning.Responses
Subject: FW: Land at Lidsey AL/20/18/OUT
Importance: High

Hi Tim,

Please find attached the latest response from the applicant to your comments regarding AL/20/18/OUT.

I look forward to receiving your response.

Thanks,

Michael

From: Clare Bartlett [REDACTED]
Sent: 19 November 2018 16:17
To: Michael Eastham
Subject: FW: Land at Lidsey
Importance: High

Hi Michael


Please see below response to the CHA's latest comments.

Kind regards

Clare

Clare Bartlett MRTPI PIEMA

Partner



Batcheller Monkhouse | Chartered Surveyors
New Bartram House, 3-5 Swan Court, Station Road, Pulborough, RH20 1RL



From: Steve Reeves <[REDACTED]>
Sent: 19 November 2018 15:53
To: Clare Bartlett <[REDACTED]> Chris Harris <[REDACTED]>
Cc: Lynn Gilbert <[REDACTED]>
Subject: RE: Land at Lidsey
Importance: High

Hi Clare,

CHA have raised a new issue about the risk that HGVs 'might over-sail the centreline when travelling south'. The drawing OCL/SR/701 Rev D shows that the route of the A29 is widened to at least 3.75m per lane, widening to 4.25 per lane at the access. Circa 10m to the south of the new access the lane widths are 4.15m each. The correct plans and the swept paths showing that two HGVs could pass each other with ease were attached to the original Transport Statement. For reference, I have attached the swept path to this email. As you can see there is plenty of room between the two HGVs as they pass each other. The camber of the A29 will also mean that HGVs will be leaning away from each other. There is no risk that HGVs would over-sail. Equally so this matter can be addressed at the detailed design stage.

CHA are referring to DWG 1749-02H in the comments about the bellmouth. This is the 'Illustrative Site Plan' of the proposal. We have shown on OCL/SR/701 Rev D the appropriate detail of the bellmouth and the reasoning for the tightness of the radii has been discussed in great detail. CHA had agreed that the detailing of the bellmouth can be agreed at the detailed design stage, once the scheme has been subjected to the Stage 2 Road Safety Audit.

It would seem that the CHA are now basing their concerns on the 'Illustrative Site Plan' DWG 1749-02H. It is not unusual for there to be some discrepancies between illustrative plans submitted as part of the application and (in this case) the 4th iteration of the highway layout plan. We have provided more than enough information to show that the access can be designed to accord with the required design standards and that the use of the access will not create an impact that can be defined as severe.

Please feel free to share this email with the Planning Authority.

Kindest regards

Steve BEng MBA MCIHT

Director

REEVES TRANSPORT PLANNING
[REDACTED]

Notice to recipient:

The information contained in this electronic mail message is intended only for the use of the individual to whom it is addressed and may contain information which is privileged and confidential, the disclosure of which is prohibited by law. If you have received this email in error please return to sender and delete copy.


Thank you for your co-operation. Consider the environment, only print out this email if absolutely necessary.



KEY:

- Visibility splay lines
- Existing Carriageway
- New Access design
- Adopted public highway

Rev	Date	Details of Issue
01	04/12/17	OPTIONAL BASE EXAMINED PROVIDED BY OTHERS: ITEM SHALL NOT BE USED FOR ANY PURPOSES OF THIS PROJECT



This document and all information herein is confidential and the intellectual property of the Arun District Council. It is not to be used for any purpose other than that for which it was prepared and it is not to be reproduced without the written permission of the Arun District Council. The copyright in this document is retained by Arun District Council.

Project	OLD COTTAGE LIDSEY
Option	OPTION TWO NEW ACCESS
Drawn	TE
Date	04/12/17
Scale of A3	1:1000
Drawn No	OCL/SS/502
Revision No	A