

From: Thomas Callaway
Sent: 07 April 2017 16:07
To: Planning.Responses
Subject: RE: Planning Consultation on AL/23/17/DOC

The surface water drainage condition may be discharged

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre,
Maitravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 27 March 2017 10:48
To: Thomas Callaway
Subject: Planning Consultation on AL/23/17/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION AL/23/17/DOC
NO:

Registered: 10-MAR-17
Site Address: Aldingbourne Farm Shop Nyton Road Aldingbourne PO20 3UL

Description of Works: Application for approval of matters reserved by condition imposed under AL/47/14/PL relating to condition No. 6

(Landscaping scheme), 7 (Plot boundary fences), 8 (Surface water drainage), 9 (Scheme to improve current site access) & 10 (Lighting)

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 10th April 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
