

From: Simon Davis
Sent: 21 April 2017 14:57
To: Planning.Responses
Subject: FW: FAO: MR Pollard REF Application AL/23/17/DOC Aldingbourne Farm Shop site, Nyton Road

Please upload to AL/23/17/DOC as correspondence

From: Simon Davis
Sent: 21 April 2017 14:56
To: [REDACTED]
Subject: FAO: MR Pollard REF Application AL/23/17/DOC Aldingbourne Farm Shop site, Nyton Road

Dear Mr Pollard,

I have just looked at your submission in respect of the lighting.

Condition 10 of AL/47/14/PL states that:

“No development shall take place until there has been submitted to, and approved by, the Local Planning Authority, a scheme that details the position, height, design and intensity of all proposed lighting within the site. The scheme shall avoid the use of floodlights, avoids night time glare and uses timers to restrict lighting during night times. The approved scheme shall be implemented on the site and retained thereafter”

Please note that the condition states that flood lights should be avoided. We will need to take a view on the proposed use of floodlighting.

I need more information from you in respect of:

1. Design of proposed column mounted lights – I need to see either an elevation of or photographic image of the type of light.
2. Your covering letter only gives the lumens value for the wall lights. Please also supply details of lumens for the flood lights and gate post lights.
3. Please also provide details on the use of timers and at what times, lighting will be switched off (by timer).

I look forward to hearing from you.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

