

[REDACTED]

---

**From:** Laura Gibbons <[Laura.Gibbons@arun.gov.uk](mailto:Laura.Gibbons@arun.gov.uk)>

**Sent:** 09 July 2019 13:04

**To:** John Carver [REDACTED]

**Cc:** Simon Davis <[Simon.Davis@arun.gov.uk](mailto:Simon.Davis@arun.gov.uk)>

**Subject:** RE: GTR Denmans Lane Fontwell

Jon,

The plan you have provided does not include invert and cover levels as previously requested. Furthermore I still also require construction detail drawings. These should be of the manholes, pipe bedding details, and soakaway. Construction detail drawings are cross-sections through these structures, with dimensions and materials clearly labelled.

Thanks,

Laura Gibbons, MEng, GMICE  
Engineer (Drainage & Coastal)

---

[Laura Gibbons](#) | Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: [laura.gibbons@arun.gov.uk](mailto:laura.gibbons@arun.gov.uk)

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and [www.chichester.gov.uk](http://www.chichester.gov.uk)



Save the environment - think before you print.

---

**From:** John Carver [REDACTED]

**Sent:** 28 June 2019 11:09

**To:** Laura Gibbons <[Laura.Gibbons@arun.gov.uk](mailto:Laura.Gibbons@arun.gov.uk)>

**Subject:** GTR Denmans Lane Fontwell

Good Morning Laura

Please find the attached drain plan and details for the above as requested , I do hope this is what need many thanks  
have anice weekend

Kind regards

Jon

---

This email has been scanned by the Symantec Email Security.cloud service.  
For more information please visit <http://www.symanteccloud.com>

---