



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 19 April 2022 14:43
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Re-Consultation on: AL/29/22/DOC

Engineers Further Comments on Condition 11

It is noted that an extension has been granted for LDC/ARUN/2021/002. However, this land drainage consent does not include consent for the new drainage connections. Please apply for land drainage consent for the two new outfalls, i.e. for the proposed connection to the new culvert and for the proposed headwall further north on the open watercourse. Please supply evidence of consent.

Please also confirm if it has been verified if there is any culvert outlet for the ditch on the western boundary?

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 08 April 2022 14:04

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Planning Re-Consultation on: AL/29/22/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: AL/29/22/DOC

Registered: 3rd March 2022

Site Address: Land At Wings Nursery Lidsey Road Woodgate PO20 3SU

Grid Reference: 493715 104134

Category: Discharge of Condi

Description of Works: Approval of details reserved by condition imposed under AL/20/21/PL relating to condition 11-discharge of flows. Decision due 28.04.22

I am able to inform you that I have received an amendment to the above application dated 8th April 2022 relating to: Further Info in response to drainage comments

[Click here to view the plans and documents](#)

If you should wish to make further representations as a result of this amendment you should click the link below and then click on 'Enter comment'.

[Click here to make further comments](#)

Please make any further comment by **24th April 2022**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Yours sincerely

Mr S Davis

Planning Case Officer-Arun District Council

Telephone: 01903 737874

Email: Simon.Davis@arun.gov.uk

PURECON_DOC (008) 0020