

Rebecca Payne

From: Amanda Scholes on behalf of Planning.Responses
Sent: 22 March 2018 11:53
To: Planning Scanning
Subject: FW: Planning Consultation on: AL/30/18/PL

From: Laura Gibbons
Sent: 22 March 2018 10:29
To: Planning.Responses
Subject: RE: Planning Consultation on: AL/30/18/PL

Pleased to observe that the proposed private treatment plant is no longer required. We therefore assume that an agreement has been reached to connect to the Southern Water sewerage system.

Laura Gibbons
Engineer (Drainage & Coastal)

[Laura Gibbons](#) | Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Paul Cann
Sent: 22 March 2018 09:37
To: Laura Gibbons
Subject: FW: Planning Consultation on: AL/30/18/PL

Paul Cann
Senior Engineer (Drainage & Coastal)

[Paul Cann](#) | Senior Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 16 March 2018 10:50
To: Paul Cann
Subject: Planning Consultation on: AL/30/18/PL

To: **Engineers (Drainage)**

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order
2015**

Planning Permission

APPLICATION AL/30/18/PL
NO:

Registered: 9th March
2018

Site Address: Land at Nyton Road and Northfields Lane Westergate and Land
off Fontwell Avenue Eastergate PO20 3UQ

Grid Reference:

Description of Works: Continuance of use without compliance with condition 24
imposed under AL/61/13/ (APP/C3810/A/14/2217385) relating
to proposed private treatment plant.

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 19-APR-18.

You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mr D Easton who can be contacted on telephone number 01903 737619.

Regards
Planning Officer

consultee_email
