

Sandra Edwards

From: Amanda Scholes on behalf of Planning.Responses
Sent: 31 May 2018 08:20
To: Planning.Scanning
Subject: FW: Application AL/32/18/PL The Wolds - Drainage

From: Simon Davis
Sent: 30 May 2018 16:36
To: Planning.Responses
Subject: FW: Application AL/32/18/PL The Wolds - Drainage

[REDACTED]

From: Laura Gibbons
Sent: 30 May 2018 15:49
To: Simon Davis
Subject: RE: Application AL/32/18/PL The Wolds - Drainage

Simon,

I have had a look over the supplied drainage details. The only issue which needs addressing before I am happy with the proposed is the need for the finish and formation level of the proposed permeable paving to be included on the plan.

After review of this, I will hopefully be happy to not apply our standard conditions, but to stipulate that it must be constructed in line with the plans submitted.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 30 May 2018 11:22
To:
Cc: Laura Gibbons
Subject: FW: Application AL/32/18/PL The Wolds - Drainage

Planning – please see Action Sheet

Laura – you have already commented on this application but they have now provided the attached to potentially avoid the need for a condition/future delay. Can you provide further advice in respect of the attached plans/details.

Kind Regards

Simon J. Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maitravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: jon [REDACTED]
Sent: 30 May 2018 11:04
To: Simon Davis
Subject: Application AL/32/18/PL The Wolds - Drainage

Dear Simon

Thank you for your reply. Please find attached all calculations and drainage construction details.

With very best wishes
Karen Shrimpton



Virus-free. www.avg.com