



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
AL/32/19/OUT

Our ref
DSA000010552

Date
12/04/2022



Dear Sir/Madam,

Proposal: Outline application with some matters reserved for the erection of 55 No. dwellings, access arrangements, sustainable drainage measures, public open space, landscaping & all other associated works (resubmission following AL/115/17/OUT). This application is a Departure from the Development Plan.

Site: AL/32/19/OUT: - Wings Nursery, Lidsey Road, Woodgate, PO20 3SU.

Southern Water has recently undertaken more detailed network modelling as part of a network growth review. The result of this assessment indicates that the additional foul sewerage flows from the proposed development will not increase the risk of flooding in the existing public sewerage network. Southern Water can hence facilitate foul disposal to service the proposed development.


Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

All other comments in our previous response dated 03/05/2019 remain unchanged and valid.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366879



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing,
West Sussex, BN13 3NX [REDACTED]

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of
H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU9304SE

Scale: 1:2500

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement.

WARNING: Unknown (UNK) material may include Bonded Asbestos Cement



Printed By: rudraps

Date: 12-4-2022

Southern Water MapGuide Browser

Requested By:

