

**From:** Simon Davis  
**Sent:** 02 June 2026 10:41  
**To:** [REDACTED]  
**Subject:** AL/32/26/DOC Lidsey Road

Dear Sam,

Our Env Health Officer has commented to say:

I have reviewed the submitted discharge of condition application including the statement by 24 Acoustics Date: 28 April 2026 Reference: R9249-2 Rev 0. Condition 5 states that “An acoustic assessment of compliance report shall then be submitted to the Local Planning Authority no later than two months after commencement of the development hereby permitted” However, the statement by 24 Acoustics just states that the windows and vents that are to be installed shall comply with the requirements the original report and no assessment has been submitted to confirm compliance. Therefore, I must recommend refusal of this application as it does not comply with the wording of condition 5.

I can give you until the 16<sup>th</sup> June to revise the submission otherwise we will need to refuse this.

Kind Regards


Simon

**Simon Davis MRTPI**  
**Principal Planning Officer**, Directorate of Growth

**T:** 01903 737874  
**E:** [simon.davis@arun.gov.uk](mailto:simon.davis@arun.gov.uk)

To register to receive notification of planning applications in your area please go to <https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd  
Littlehampton, West Sussex, BN17 5LF  
[www.arun.gov.uk](http://www.arun.gov.uk)



Connect with us: [Facebook](#) | [X](#) | [Instagram](#)