

[REDACTED]

From: Daniel Vick
Sent: 26 April 2019 10:09
To: Planning Scanning
Subject: FW: AL/36/19/DOC

[REDACTED]

Dan

From: Daniel Vick
Sent: 26 April 2019 10:05
To: [REDACTED]
Subject: AL/36/19/DOC

Mr Catt,

I have received the following response from our drainage engineer:-

Engineers Comments Regarding Condition 4- surface water drainage

1. Please can a layout plan be provided which shows the location of the trial holes and groundwater monitoring points. The map provided does not include hole numbers.
2. The layout plan will need to be updated to include invert and cover levels of the soakaway.
3. Construction detail drawings need to show 100mm coarse sand bed and surround, and permeable geotextile.
4. Please provide construction detail drawings of pipe bedding and surround.

Please provide the requested information within two weeks. If the information is not provided within that timescale the application will be refused.

Daniel Vick

Daniel Vick | Area Team Leader, Planning Services, Arun District Council | Location: Phoenix House, Maltravers Road, Littlehampton,
BN17 5LF

[REDACTED]

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.