

[REDACTED]

From: Joshua Catt [REDACTED]
Sent: 01 May 2019 09:51
To: Daniel Vick
Cc: Laura Gibbons
Subject: RE: AL/36/19/DOC

Morning Daniel,

Please see attached information from the engineers to address the comments below. Please advise if anything else is required and we will get it across to you asap.

Kind regards,

Josh Fenwick-Catt MCAT
Chartered Architectural Technologist

for Harris Irwin Associates

Aske Stables
Aske
Richmond
North Yorkshire
DL10 5HG

[REDACTED]

This email and all the attachments it may contain are confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Harris Irwin Associates Limited. If you are not the intended recipient, be advised that you have received this email in error and that any use, dissemination, printing, forwarding or copying of this e-mail is strictly prohibited. Please contact the sender if you have received this e-mail in error. Registered in England and Wales No. 5332633.



Please consider your environmental responsibility before printing this e-mail

From: Daniel Vick <Daniel.Vick@arun.gov.uk>
Sent: 26 April 2019 10:05
To: Joshua Catt [REDACTED]
Subject: AL/36/19/DOC

Mr Catt,

I have received the following response from our drainage engineer:-

[Engineers Comments Regarding Condition 4- surface water drainage](#)

1. Please can a layout plan be provided which shows the location of the trial holes and groundwater monitoring points. The map provided does not include hole numbers.
2. The layout plan will need to be updated to include invert and cover levels of the soakaway.
3. Construction detail drawings need to show 100mm coarse sand bed and surround, and permeable geotextile.
4. Please provide construction detail drawings of pipe bedding and surround.

Please provide the requested information within two weeks. If the information is not provided within that timescale the application will be refused.

Daniel Vick

Daniel Vick | Area Team Leader, Planning Services, Arun District Council | Location: Phoenix House, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37771 | External: +44 (0) 1903 737771 | E-mail: daniel.vick@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
