



Engineers Comments Regarding Surface Water Drainage

The following points need to be addressed before discharge of conditions can be recommended:

1. Please provide a construction detail for a concrete pipe bed and surround for where pipe depths are less than 900mm. Plus amend note as to when each surround should be used (Granular where cover to crown is greater than 1200mm in vehicular areas, or greater than 900mm elsewhere. For shallower depths concrete surround.)
2. Please confirm the dimensions of the trial pits within the Surface Water Drainage Notes.


Kind Regards

Sarah Burrow
Engineering Assistant, Engineers



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: AL/36/20/DOC

Registered: 4th May 2020

Site Address: The Studio Tudor Drive Westergate Aldingbourne PO20 3YT

Description of Works: Approval of details reserved by condition imposed under ref AL/34/17/HH relating to Condition Nos 3 - materials & finishes and 4 - surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **19th June 2020**.


Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Finlay Gardner

Planning Case Officer- Arun District Council



PLCONIDCC (CDB) 2020