

Sandra Edwards

From: Amanda Scholes on behalf of Planning.Responses
Sent: 16 May 2017 09:25
To: Planning Scanning
Subject: FW: Planning Consultation on AL/38/17/DOC

From: Paul Cann
Sent: 15 May 2017 11:58
To: Planning.Responses
Subject: RE: Planning Consultation on AL/38/17/DOC

Comments in respect to surface water drainage condition;

To support the proposal, the applicant needs to provide a construction detail (cross section) for the crated soakaway, to include all relevant levels of incoming pipes, etc. Silt trap manhole detail is also to be provided.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF


Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 09 May 2017 11:48
To: Paul Cann
Subject: Planning Consultation on AL/38/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION AL/38/17/DOC

NO:

Registered: 27-APR-17
Site Address: The Thatched House Littleheath Road Aldingbourne BN18 0SR
Description of Works: Applicaiton for approval of matters reserved by condition imposed under AL/127/16/HH relating to conditions 3 for samples of materials & finishes & 5 for surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditons relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 23rd May 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Richard Temple who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_cor_email
