

[REDACTED]

From: Laura Gibbons
Sent: 07 August 2018 14:28
To: Simon Davis
Subject: RE: ALDINGBOURNE GOSPEL HALL - APPLIC REF. AL/38/18/PL

Hi Simon,
The condition will still be required as they have not completed winter groundwater monitoring, and the percolation tests were completed too deep.
Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF

[REDACTED]

Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 03 August 2018 14:39
To: Laura Gibbons
Subject: RE: ALDINGBOURNE GOSPEL HALL - APPLIC REF. AL/38/18/PL

Hi Laura,

This has been submitted to overcome the need for the condition or a revised version of the condition.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Pla|
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF

[REDACTED]



From:

Robin Reay [REDACTED]

Sent: 03 August 2018 14:21

To: Simon Davis

Cc: Laura Gibbons

Subject: ALDINGBOURNE GOSPEL HALL - APPLIC REF. AL/38/18/PL

Simon,

Notwithstanding what we said earlier today, can I submit the amended drainage proposals for the Gospel Hall additional parking – attached (and copied to Laura Gibbons). The proposed drainage now incorporates permeable paving.

The applicant is very keen to have submitted amended drainage proposals to the Council ahead of the planning committee next Wednesday.

Robin

Robin Reay MRTPI
Luken Beck MDP Ltd,
30 Carlton Crescent,
Southampton SO15 2EW



Development ♦ Management ♦ Planning