

**From:** Laura Gibbons

**Sent:** 02 October 2018 12:18

**To:** 'Robin Reay'; Simon Davis

**Cc:** Simon Davis

**Subject:** RE: ALDINGBOURNE GOSPEL HALL - APPLIC REF. AL/38/18/PL - DRAINAGE CONDITION DISCHARGE

Hi Robin,

I will need to see calculations and construction detail drawings.

When were the infiltration tests completed? If they were completed outside of winter I will need to see a factor of safety applied to the design (please refer to CIRIA R156/ CIRIA C609 for these).

Thanks,

Laura Gibbons, MEng, GMICE  
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,  
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: [laura.gibbons@arun.gov.uk](mailto:laura.gibbons@arun.gov.uk)

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and [www.chichester.gov.uk](http://www.chichester.gov.uk)



Save the environment - think before you print.

**From:** Robin Reay [REDACTED]

**Sent:** 21 September 2018 15:05

**To:** Simon Davis

**Cc:** Laura Gibbons

**Subject:** ALDINGBOURNE GOSPEL HALL - APPLIC REF. AL/38/18/PL - DRAINAGE CONDITION DISCHARGE

Simon,

Following the approval of the additional parking for the Aldingbourne Gospel Hall, can I address the discharge of Condition 3 - drainage please.

I appreciate that there will need to be a formal Discharge of Condition application submitted for the condition but it would be very helpful to the Gospel Trust if we could submit and agree drainage soakaway calculations asap so that the DoC application can then proceed smoothly. To this end, please find attached soakaway calcs that the Trust have recently produced from the site, plus a response to the calcs from the Trust's Drainage Consultant, Malcolm McKerney.

I've included Laura Gibbons into this e-mail so that hopefully she can give a view prior to submission of the DoC application.

Thanks,

Robin.

Robin Reay MRTPI  
Luken Beck MDP Ltd,  
30 Carlton Crescent,3  
Southampton SO15 2EW



Development ♦ Management ♦ Planning