

Amber Willard

From: Craig Milligan
Sent: 13 August 2021 13:48
To: Amber Willard
Subject: FW: al/39/21/pl
Attachments: Site Plan Boiler Flue location.pdf; Site Plan Distance to neighbours.pdf; Revised Certificate P4079 C002 -1[1].pdf; Biomass Emissions Screening tool v7.pdf; Emission Rate.xlsx

Follow Up Flag: Flag for follow up
Flag Status: Flagged

Hi Amber,

I have had a discussion with the applicant and also received the below information. Having received the further information I am satisfied that the noise from the biomass boiler is unlikely to cause a noise nuisance to neighbouring properties.

I am therefore satisfied that a noise condition shall not be necessary.
Kind regards
Craig

Craig Milligan
Environmental Health Officer, Technical Service



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)



From: Andrius Lescinkas [REDACTED]
Sent: 10 August 2021 16:33
To: Craig Milligan [REDACTED]
Cc: Michael Powe [REDACTED]
Subject: RE: al/39/21/pl

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hello Craig,

Further to your conversation with Mike,

Thanks for your time just now, as discussed most councils are happy that we provide the set noise figures for the boilers, in this case noise is further mitigated by the enclosed container housings.

The flue termination point is facing upwards and is at a height of 5.9 M, the closest receptors are around 70 M or more so the noise from the flue exit should be very minimal.

There is similar equipment on site and there have been no complaints in past years.

Please do not hesitate to contact me if you need any more information.

Many Thanks

Mike Powell | Managing Director [REDACTED]
Glen Farrow UK Ltd [REDACTED]
Glendum Close, Pinchbeck, Spalding, Lincs, PE11 3DQ

All work is carried out and goods are supplied subject to our Terms and Conditions of Sale which can be found on our website [here](#).

Approved / Accredited by:

Anglian Water | CHAS | ConstructionLine | GasSafe (95542) | NIC EIC | OFTEC | Safecontractor

Glen Farrow UK Ltd • Registered Office: as above • Registered in England No: 1045218 • VAT No: 119 322 488

The information in this email and any files transmitted with it is confidential and intended solely for the addressee. If you are not the intended recipient, any disclosure, copying, distribution or action taken in reliance on its contents is prohibited and may be unlawful. If you have received this email in error please notify the sender.