

Sandra Edwards

From: Simon Davis
Sent: 18 June 2018 10:54
To: Planning Scanning
Subject: FW: The Coach House, Norton Lane AL/43/18/DOC

Application supporting letter

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: LLP Planning [REDACTED]
Sent: 18 June 2018 08:28
To: Simon Davis
Subject: Re: The Coach House, Norton Lane AL/43/18/DOC

Dear Mr Davis,

Thank you for your email. I can confirm that the results from the winter ground water monitoring were as follows :

Two trial pits were dug on the 23rd February 2018 within the vicinity of the proposed SUD. This was left uncovered for two days and was at a depth of 1.5 metres. There were three inspections, morning, evening and the following water and there was no water in the pits during any of those inspections. I hope this clarifies this.

Both invert levels for the pipes would be 900mm below ground level.

Can you please let me know if you require anything further.

Kind regards,

Leah

On 7 Jun 2018, at 16:57, Simon Davis <Simon.Davis@arun.gov.uk> wrote:

From: Simon Davis
Sent: 07 June 2018 16:58
To: [REDACTED]
Subject: The Coach House, Norton Lane AL/43/18/DOC

Dear Ms Mew,

Please see attached Drainage Engineer response and please provide the requested details.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.