

From: Simon Davis
Sent: 27 June 2018 14:53
To: Planning.Responses
Subject: FW: Re : The Coach House, Norton Lane AL/43/18/DOC

Final Engineers response

From: Laura Gibbons
Sent: 27 June 2018 14:48
To: Simon Davis
Subject: RE: Re : The Coach House, Norton Lane AL/43/18/DOC

Simon,

The revised drainage layout provides the additional storage capacity as requested and the soakaway has been raised to 1.2m deep as requested. Therefore, based on the supplied information, I recommend that the condition is discharged.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 22 June 2018 12:05
To: Planning.Responses
Cc: Laura Gibbons
Subject: FW: Re : The Coach House, Norton Lane AL/43/18/DOC

Planning – See Action Sheet

Laura – for your further comment

Kind Regards



From: [REDACTED]

Sent: 22 June 2018 08:02

To: Simon Davis

Subject: Re : The Coach House, Norton Lane

Good morning Simon,

Please find attached our revised plan for the Condition release as per your email.

If you have any queries regarding the attached then please let me know.

Kind regards,

Leah