

From: Fiona Fitzgerald
Sent: 22 July 2014 12:00
To: Simon Davis
Subject: AL/47/14/PL

Dear Simon,

I have no adverse comments on the application. However, where placed near a boundary there should be a space of 3 metres clear to the boundary from any caravan. Additionally, adequate arrangements for foul drainage will be required for the units which, if consent is given, will have to comply with site licence conditions(via an application for a Caravan Site Licence as this is an application for a permanent site) in relation to fire safety, distances between caravans, roadways, site electrics and overall maintenance of the site.

Please ensure the applicant is aware that they will need to apply to Environmental Health for a Caravan Site Licence separately to the Planning Application.

I would be grateful if you would let me know if this application gains consent.

Regards

Fiona Fitzgerald

Fiona Fitzgerald | Environmental Health Officer, Environmental Health Department, Arun District Council | Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37674 | External: +44 (0) 1903 737674 | E-mail: Fiona.Fitzgerald@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.