

Vivid Design Studio Ltd
Paddock View
Calcot Mount Business Park
Calcot Lane
Curdridge
SO32 2BN

Date: 22nd June 2021

Please ask for: Mr S Davis
Tel: 01903 737874

Your Ref:

Our Ref: AL/49/21/DOC

Dear Mr Dudley,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref AL/64/20/PL relating to Condition Nos 5 - pre-commencement site meeting with Tree Officer, 6 - mitigation method statement, 7 - archaeology, 8 - Construction & Environmental Management Plan, 13 - detailed level survey, 14 - materials & finishes, 15 - details of all new screen walls & fences, 16 - landscaping, 18 - energy efficiency measures, 19 - covered & secure cycle parking spaces, 21 - broadband, 22 - charging of electric vehicles and 25 external lighting.

Springfield Hook Lane Aldingbourne PO20 3TE

Notification regarding the above application:

Condition Number 25

No external lighting shall be installed on site until plans showing the type of light appliance, the height and position of fitting, illumination levels and light spillage have been submitted to and approved in writing by the Local Planning Authority. The scheme should seek to conform with the recommendations within BS5489:1-2013 but also minimise potential impacts to any bats using the trees, hedgerows, and buildings by avoiding unnecessary artificial light spill through the use of directional light sources and shielding. The lighting approved shall be installed and shall be maintained in accordance with the approved details.

Reason: In the interests of the amenities of the area, the site biodiversity (particularly in respect of bats), the interests of minimising crime and to minimise unnecessary light spillage outside the development site in accordance with policies QE SP1, QE DM2 & ENV DM5 of the Arun Local Plan.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

The Councils Ecologist has not responded to the consultation. However, it is unclear whether the lighting unit proposed meets the specific requirements of the condition "... also minimise potential

impacts to any bats using the trees, hedgerows, and buildings by avoiding unnecessary artificial light spill through the use of directional light sources and shielding". Typically, this would require a downlighter or shielded light but the proposal is for neither. As such, the submission of details cannot be agreed at this time and a resubmission will be required.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning