



from
**Southern
Water**

Beata Libiszewska
Markides Associates Ltd
The Bridge
81 Southwark Bridge Road
London
SE1 0NQ

Your ref

Our ref
DSA000005273

Date
04 February 2022

Contact
[REDACTED]

Dear Ms Libiszewska,

Level 1 Capacity Check Enquiry: Land at SRC Recycling, Eastergate, Chichester, West Sussex, PO20 3RU.

We have completed the capacity check for the above development site and the results are as follows:

Foul Water

There is currently inadequate capacity within the foul sewerage network to accommodate a foul flow of 0.72 l/s for the above development at manhole reference SU94054601. The proposed development would increase flows to the public sewerage system which may increase the risk of flooding to existing properties and land. Additional off-site sewers or improvements to existing sewers will be required to provide sufficient capacity to service the development. Southern Water has a duty to provide Network capacity from the point of practical connection (point of equivalent or larger diameter pipe) funded by the New Infrastructure Charge.

Southern Water aim to provide this within 24 months following the date that planning has been granted for developments not identified as strategic sites in our current business plan. Strategic sites are larger developments and will often take longer than 24 months for a full solution to be provided.

The nearest point where capacity is currently available is at Lidsey WTW which is located approximately 2.4 km towards south of the proposed development site. Rights are not issued for a direct connection to Wastewater Treatment Works (WTW). Please note that connection to the WTW will have to be agreed by Southern Water Services before being carried out.

New Infrastructure Charging

Please note as of 1st April 2018 we have moved to the "New Connections Services Charging Arrangements". We understand that this may cause uncertainty for customers, particularly where they may have already committed to a development based on previous charging arrangements. We have worked with our stakeholders and Water UK to agree a set of principles by which we will base

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366870

our charges. Please read through our new charging arrangement documents available at the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

Alternatively, New Appointees and Variations (NAV's), also known as 'inset' companies, can provide new connection services or take ownership of the new water and wastewater connection infrastructure provided for a new development. NAV's are appointed by Ofwat and replace the regional water company. It is for the developer to choose whether to use a NAV or the regional water company to supply services for new sites, according to certain legal criteria.

Connecting to our network

It should be noted that this information is only a hydraulic assessment of the existing sewerage network and does not grant approval for a connection to the public sewerage system. A formal Sewer Connection (S106) application is required to be completed and approved by Southern Water Services. To make an application visit: [Developer Services Portal \(southernwater.co.uk\)](https://southernwater.co.uk/developing-building/connection-charging-arrangements)

Please note the information provided above does not grant approval for any designs/drawings submitted for the capacity analysis. The results quoted above are only valid for 12 months from the date of issue of this letter.

Should it be necessary to contact us please quote our above reference number relating to this application by email at : [REDACTED]

Yours sincerely,

Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development