

From: Paul Cann
Sent: 15 May 2017 12:12
To: Planning.Responses
Subject: RE: Planning Consultation on AL/50/17/DOC

Comments in respect to surface water drainage condition;

To support the proposal, the applicant needs to provide construction details (cross section) for the crated soakaways/permeable paving, to include all relevant levels of incoming pipes, etc. Silt trap manhole detail is also to be provided. Hydraulic calculations should also be supplied.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 09 May 2017 16:18
To: Paul Cann
Subject: Planning Consultation on AL/50/17/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: AL/50/17/DOC

Registered: 28-APR-17

Site Address: Land West of Fontwell Avenue Fontwell Avenue Eastergate
PO20 3RU

Description of Works: Application for approval of details reserved by condition imposed under AL/121/16/PL relating to conditions 4-surface water drainage, 5-scheme for protecting proposed dwellings from noise & 6-scheme to deal with contamination risk.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 23rd May 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
