

From: Christopher Davis <Christopher.Davis@arun.gov.uk>
Sent: 05 November 2019 10:27
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: AL/51/19/PL - Springfield and land to rear, Hook Lane, Aldingbourne, PO20 3TE
Importance: High

EH comments in relation to AL/51/19/PL - Springfield and land to rear, Hook Lane, Aldingbourne, PO20 3TE

Having now evaluated the proposed development and formulated my conclusions I would state that based on the requirements of the NPPF and NPPG, this development falls into category 2 (below):

1. ~~No comments~~
2. **Conditions or Informatives requested**
3. ~~Refusal recommended~~

I therefore put forward the following;

DEMOLITION / CONSTRUCTION PHASES

Conditions

To minimise the potential of complaint of dust / noise / lighting the following condition should be applied to the application:

1. No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:-
 - a. An indicative programme for carrying out of the works
 - b. Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works
 - c. Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s)
 - d. Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination
 - e. the parking of vehicles of site operatives and visitors
 - f. loading and unloading of plant and materials, including permitted times for deliveries
 - g. storage of plant and materials used in constructing the development

- h. the erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate
- i. the provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders)
- j. measures to control the emission of dust and dirt during construction
- k. a scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted

Reasons

To protect the amenity of local residents in accordance with Policy QE SP1 of the Adoption Arun Local Plan 2011 – 2031

Informatives

The granting of this planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of the Environmental Protection Act 1990 be received. For further information please contact the Environmental Health Department on (01903) 737555

Kind regards

Christopher Davis
Senior Environmental Health Officer

Environmental Health Department
(01903) 737695 (direct line)

Arun Civic Centre | Maltravers Road | Littlehampton | BN17 5LF

www.arun.gov.uk/eh

