




From: Liz Annalls [REDACTED]
Sent: 13 July 2020 07:50
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: AL/51/20/PL

Application No: AL/51/20/PL
Site Address: Tyrone House Norton Lane Norton Aldingbourne PO20 3NH
Description of Works: Demolition of existing house & outbuildings & erection of 1 No dwelling & garage (resubmission following AL/29/20/PL).

Bats

The lighting scheme for the site will need to take into consideration the presence of bats in the local area and the scheme should minimise potential impacts to any bats using the trees, hedgerows and buildings by avoiding unnecessary artificial light spill through the use of directional light sources and shielding.

We require that a bat brick is integrated into the building onsite facing south/south westerly positioned 3-5m above ground.

The hedgerows on site are used by bats for commuting and foraging and will need to be retained and enhanced for bats. This will include having a buffer strip around the hedgerows (5m) and during construction fencing should be used to ensure this area is undisturbed. Any gaps should also be filled in using native hedge species to improve connectivity. Conditions should be used to ensure this.

Nesting Birds

Any works to the trees or vegetation clearance on the site should only be undertaken outside of the bird breeding season which takes place between 1st March – 1st October. If works are required within this time an ecologist will need to check the site before any works take place (within 24 hours of any work).

We would like a bird box to be installed on the building / and or tree within the garden of the property.

Net Biodiversity Gain

In line with Policy ENV DM5 of the Arun District Local Plan information on Biodiversity Net Gain needs to be provided as part of the planning application prior to determination. We are satisfied that the enhancements proposed within section 6 of the Preliminary Ecological Appraisal (April 2020) are suitable and a condition should be used to ensure these take place.

Kind Regards

Liz



Liz Annalls
Environment Officer
Environmental Protection
Chichester District Council



From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 10 July 2020 16:34
To: Environmental Strategy
Subject: Planning Consultation on: AL/51/20/PL

To: **Ecology Advisor**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015 - Articles 16 & 18 Consultation before the grant of permission

Planning Permission

Application No:	AL/51/20/PL
Registered:	8th July 2020
Site Address:	Tyrone House Norton Lane Norton Aldingbourne PO20 3NH
Grid Reference:	492748 106125
Description of Works:	Demolition of existing house & outbuildings & erection of 1 No dwelling & garage (resubmission following AL/29/20/PL).

The Council have received the above application.

[Click here to view the application details](#)

This application has been identified as CIL Liab. Therefore please be aware that, in accordance with Appendix 2 of the Arun CIL Charging Schedule, your consultation response should only include requests for Section 106 for onsite mitigation, Pagham Harbour Management Contributions (if applicable) or Affordable Housing. Off Site mitigation measures directly related to this development should be dealt with by condition if possible to ensure the scaling back of Section 106 if possible. CIL contributions will be used for off site infrastructure mitigation schemes. Therefore if this proposal triggers the need for off site mitigation, please ensure that you engage in the CIL Infrastructure List Consultation process upon receipt of a consultation letter.

Should you have any comments to make, these should be sent by replying to this email by 13th August 2020 . You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://www.planningportal.co.uk/info/200207/appeals> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Amy Myer

Planning Officer- Arun District Council

Telephone: 01903 737776

Email: amy.myer@arun.gov.uk

PLCONSULT (COB) 2020

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

LEGAL DISCLAIMER

Communications on or through Chichester District Council's computer systems may be monitored or recorded to secure effective system operation and for other lawful purposes.

LEGAL DISCLAIMER

This e-mail and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. However, any views or opinions presented are solely those of the author and do not necessarily represent those of Chichester District Council.

If you are not the intended recipient or the person responsible for delivering the e-mail to the intended recipient, be advised that you have received this e-mail in error and that any use, dissemination, forwarding, printing or copying of this e-mail is strictly prohibited.

Communications on or through Chichester District Council's computer systems may be monitored or recorded to secure effective system operation and for other lawful purposes.

If you have received this e-mail in error please notify the Chichester District Council administrator.

