




TSU – please add revised drainage drawings to the file, and supersede previous versions as relevant.

Sarah – please review and provide additional comments in respect of these

Many thanks
Amy




Dear Amy

Please find attached revised drainage drawings and calcs addressing the issues previously raised by the drainage officer. Please also forward the below to Sarah.

Thanks

Ben



Hi Ben


Please find attached updated drawings and SuDS report.

Regarding the comments from Sarah Burrow:

- Network calculations have been carried out and can be found attached.
- Flotation calcs have been undertaken by the attenuation tank manufacturer and have been attached
- Construction details are also attached.
- Using diffuser units to discharge roof surface water to permeable paving is not viable due to the levels on site with them being too deep and for the requirement to have the diffuser units 5m away from the building. At this point of connection it will strike ground water levels.
- An OWC application is currently underway and will be submitted shortly

Kind regards

Chris Slade **FIHE**
CGS Civils Ltd



Drainage Design | SuDS | Flood Risk Assessments | Highways | External Works

Richard Cobden House | Lion Street | Chichester | West Sussex | PO19 1LW

This e-mail and any attachment is intended for the named addressee(s) only, or person authorised to receive it on their behalf. The content should be treated as confidential and the recipient may not disclose this message or any attachment to anyone else without authorisation. Unauthorised use, copying or disclosure may be unlawful. If this transmission is received in error please notify the sender immediately and delete this message from your e-mail system. Any view expressed by the sender of this message or any attachment may be personal and may not represent the view held by the Company. All electronic transmissions to and from the Company are recorded and may be monitored. CGS Civils Ltd, Registered in England No. 8546902, VAT Registration No. 169950851.