

[REDACTED]

From: Sue Howell <Sue.Howell@arun.gov.uk>
Sent: 10 July 2019 12:58
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Consultation on AL/52/19/DOC

Hi Simon

I have had a look at the revised drawing 215818 L02 Rev C, but it is still lacking in the basic information that is required.

The applicant has not submitted a landscape plan which clearly shows the proposed 'Bund mixed planting' with the species and the **actual quantities** proposed. Also the shrubs and hedgerow area shown to the front needs the detail to be provided in plan form along with list of proposed planting species and **actual quantities**, plus planting density and size at time of planting.

Please request that this information is submitted for approval before I could recommend the discharge of condition 7 on this application AL/52/19/DOC.

Regards

[Sue Howell](#) | Leisure and Landscape Officer, Greenspace, Engineering and Emergency Planning, [Arun District Council](#) | Location: Bognor Regis Town Hall, Clarence Road, Bognor Regis, West Sussex, PO21 1LD
Internal: 37943 | External: +44 (0) 1903 737943 | E-mail: sue.howell@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 09 July 2019 10:03
To: Sue Howell <Sue.Howell@arun.gov.uk>
Subject: RE: Planning Consultation on AL/52/19/DOC

Hi Sue,

Please see attached revised plan received today.