

Lynnyrd Wolfe

From: Simon Davis
Sent: 19 July 2019 16:00
To: Planning.Responses
Subject: FW: Planning Consultation on AL/52/19/DOC
Attachments: Amended landscape plan L02 Rev D.pdf

Please see Action Sheet

From: Nina Harde [REDACTED]
Sent: 19 July 2019 14:41
To: Simon Davis [REDACTED]
Cc: Sue Howell [REDACTED]
Subject: RE: Planning Consultation on AL/52/19/DOC

Dear Simon


Please find attached our amended landscape plan for the above application.

Kind regards

Nina

NINA HARDEN
SALES CO-ORDINATOR

SCANDIA-HUS LTD
SCANDIA-HUS BUSINESS PARK, FELCOURT ROAD, FELCOURT, EAST GRINSTEAD, W. SUSSEX RH19 2LP



From: Simon Davis [REDACTED]
Sent: 17 July 2019 10:24
To: Gavin Pearson [REDACTED]
Subject: RE: Planning Consultation on AL/52/19/DOC

Dear Gavin,

Further to the below email (which still needs a further submission), I also need to request a change to the hard surfacing on the landscaping plan. You propose gravel to the driveway/parking areas. However, this is at odds with the approved surface water drainage scheme which proposed permeable paving laid on coarse graded aggregate. These plans needs to match. See attached approved drainage plan

Kind Regards

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Simon Davis

Sent: 10 July 2019 14:36

To: [REDACTED]

Subject: FW: Planning Consultation on AL/52/19/DOC

Dear Gavin,

Please see below further comments.

From: Sue Howe [REDACTED]

Sent: 10 July 2019 14:36

To: Simon Davis [REDACTED]

Subject: RE: Planning Consultation on AL/52/19/DOC

Hi Simon

I have had a look at the revised drawing 215818 L02 Rev C, but it is still lacking in the basic information that is required.

The applicant has not submitted a landscape plan which clearly shows the proposed 'Bund mixed planting' with the species and the **actual quantities** proposed. Also the shrubs and hedgerow area shown to the front needs the detail to be provided in plan form along with list of proposed planting species and **actual quantities**, plus planting density and size at time of planting.

Please request that this information is submitted for approval before I could recommend the discharge of condition 7 on this application AL/52/19/DOC.

Regards